

FIREWORKS STAND DISTANCE REGULATIONS

- Canopies within 10 feet of a stand shall be considered an extension of the stand for distance requirements.
- Fans/coolers must be located at least 5 feet from the stand and not blocking the exit opening.
- Motor vehicles shall not be parked within 20 feet of the stand during sales hours.
- Motor vehicles shall not be parked within 20 feet of seatrain containers at all times.
- Fireworks stands shall be a minimum of 25 feet from any building.
- Seatrains shall a minimum of 25 feet from the fireworks stand or any other building.
- Generators shall be a minimum of 25 feet from the fireworks stand.
- All weeds and combustible materials, including shipping cartons, shall be cleared a minimum of 30 feet from the stand.
- No smoking or lighting of fireworks within 50 feet of the stand or stored fireworks.
- Fireworks shall not be stored within 100 feet of any gasoline pump.