

SAFETY REGULATIONS
FOR THE SALE OF “SAFE AND SANE” FIREWORKS

Electrical

- All electrical/spark-producing appliances (fans, coolers, air conditioners etc.) are prohibited inside the stand.
- Approved temporary lighting may be installed in the stand and must have a guard protecting the bulb/fixture and all wiring and fixtures must be three-wire and grounded.
- No switches, electrical receptacles or splices are permitted within the stand.
- Extension cords to the stand must be heavy duty, minimum of 15 amp capacity and protected from vehicle damage. Romex wiring is not an acceptable extension cord.

General

- Water misters are not allowed in the stands.

- No person shall be permitted to sell or otherwise participate in the sale of fireworks other than a member (or their spouse) of the organization or a volunteer who is associated with the organization having a permit.
- No person under the age of 18 shall sell, or handle for sale, any Safe and Sane Fireworks.
- Fireworks shall not be sold to persons under the age of 16 years.
- One (1) member per every four lineal feet of stand is permitted in the stand at one time (i.e. if the stand is 32 feet long, 32 divided by 4 = 8 members allowed).
- The sales hours for fireworks are between 9:00 a.m. and 10:00 p.m. The sales period begins at 12:00 p.m. June 28 and ends at 10:00 p.m. July 4.
- All trash shall be removed from the premises and the fireworks stand each evening at the close of business.
- Sleeping or remaining in the stand after the close of business is forbidden.
- “NO SMOKING” signs with four (4) inch minimum letters shall be conspicuously posted on all four sides of the stand. Enforcement of the NO SMOKING policy is mandatory.
- Barbeques and open flame devices (lanterns, candles, etc.) are not allowed.
- Fuel for portable generators is not allowed to be kept on the premises.
- Each stand shall have at least two (2) portable fire extinguishers. One (1) 2-½ gallon pressurized water fire extinguisher for Class-A fires and one (1) 2A-10BC rated extinguisher. Portable extinguishers shall be currently certified, accessible, and the Fire Inspector shall approve the locations. (Mounting not required).