

# Bath Fire Department

---

## Home Inspection Checklist

Adoption \_\_\_\_\_ Foster Care \_\_\_\_\_

Date \_\_\_\_\_

Name \_\_\_\_\_

Address \_\_\_\_\_

Phone \_\_\_\_\_

Test Smoke Detectors; Battery \_\_\_\_\_ Hardwired \_\_\_\_\_

Smoke detectors shall be less than 10 years old and be located one on each level, hallway ***and*** inside each sleeping room.

Carbon Monoxide Detector; Battery \_\_\_\_\_ Hardwired \_\_\_\_\_

CO detectors shall be placed in a centralized living space

Fire Extinguisher; Yes \_\_\_\_\_ No \_\_\_\_\_ (At least one) Typically in the kitchen

Recommend one in basement and garage

Fire extinguisher is required; recommend a metal valve unit, a minimum of 5 pound ABC with UL Listing

All storage areas garage, and basement; must be kept in neat and orderly manor with access to electrical panel.

Child protective caps installed in exposed, unused, electrical outlets