



* FOR DEPTHS OF LESS THAN 3' OF COVER USE DUCTILE IRON PIPE OR CEMENT SLURRY ENCASED PIPE TO THE APPROVAL OF THE CITY ENGINEER.

** 8" - 12" PIPE, 42" MIN. COVER
OVER 12" PIPE, 48" MIN. COVER

CITY of CORCORAN • Department of Public Works

Standard Drawing for:

SEWER LATERAL

APPROVED:  City Engineer

05/19/08
Date

Revised:

SS-7