

ADDENDUM NUMBER 1

FOR THE

CITY OF CORCORAN

**WATER TREATMENT PLANT STORMWATER BASIN
RELOCATION**

June 27, 2023



OWNER:

**City of Corcoran
832 Whitley Avenue,
Corcoran CA, 93212
Phone: (559) 992-2151**

PREPARED BY:

**A&M Consulting Engineers
220 N Locust Street
Visalia, CA 93291
(559) 429-4747**

ADDENDUM NUMBER 1

The following additions, deletions or modifications shall become part of the Contract Documents for the City of Corcoran Water Treatment Plant Stormwater Basin Relocation Project:

CONTRACTOR QUESTIONS:

Q1: Is there a designated location where the excess dirt can be dumped?

A1: The excavated dirt will be used to backfill the old basin location across the street. Dirt will be compacted to 90% relative compaction.

Q2: Can you please provide an engineer estimate for above-listed project?

A2: The engineer's estimate is \$100,000.

Q3: Do you have any grades for the contours?

A3: The grading plan (GR-1.01) shows all proposed and existing grades.

Q4: Do you have a preferred place for the spoil?

A4: The excavated dirt will be used to backfill the old basin location across the street. Dirt will be compacted to 90% relative compaction.

Q5: What height will the Chain Link double gate be? Will the Chain Link items use barbed wire? Will they use top and bottom rails?

A5: The height of the chain link double gate will be 8'. Yes, barbed wire. Only top rails.

REVISION TO BID DOCUMENTS:


Further clarification has been added to the following bid item number 5:

Bid Item 5: Construct storm drainage system complete and in place

This work shall consist of installing a stormwater drain inlet, 24” Reinforced Concrete pipe, outfall structure, drain inlet, grading, gravel roads, all trench shoring & benching, all asphalt patchwork, installing fencing, hauling of excavated soil, compaction, abandoning the existing Stormwater system as shown in the plan, all work called out on the plans, and all testing as required by the “Greenbook”. All costs associated with this item shall be included in the lump sum price bid for Bid Item No.5, and no additional payment will be made.

--

NOTE: One copy of this Addendum Number 1 shall be signed by the Contractor and must be submitted with the bid as acknowledgment of receipt and acceptance of this Addendum Number 1.

Prepared by:  6/27/23
Orfil Muniz, P.E. Date
A&M Consulting Engineers

Accepted by: _____
Contractor (Signature) Date