

ADDENDUM NUMBER 3

FOR THE

CITY OF CORCORAN

**2020 WASTEWATER TREATMENT PLANT
MODIFICATIONS**

January 25, 2021



OWNER:
City of Corcoran
832 Whitley Avenue
Corcoran, CA 93212

PREPARED BY:
A&M
220 N Locust Street
Visalia, CA 93291

ADDENDUM NUMBER 3

The following additions, deletions, or modifications shall become part of the Contract Documents for the City of Corcoran 2020 Wastewater Treatment Plant Modifications project:

REVISIONS TO INSTRUCTIONS TO BIDDERS:

REVISION:

8. The Contractor shall begin Work within fourteen (14) calendar days after receiving the Notice to Proceed by the Owner. The Notice to Proceed will be issued on a date mutually agreed upon by the Owner and Contractor. However, the Notice to Proceed will be issued no later than sixty (60) calendar days following issuance of the Notice of Award. The Contractor shall complete all Work within **two hundred seventy (270) calendar days** following the date of the Notice to Proceed. Time is of the essence and time of completion as specified will be enforced.

REVISIONS TO AGREEMENT BETWEEN OWNER AND CONTRACTOR FOR CONSTRUCTION CONTRACT (STIPULATED PRICE):

REVISION:

4.02 Contract Times: Days

A. The Work will be substantially completed within **270 calendar days** after the date when the Contract Times commence to run as provided in Paragraph 4.01 of the General Conditions and completed and ready for final payment in accordance with Paragraph 15.06 of the General Conditions within 0 days after the date when the Contract Times commence to run.

--

REVISIONS TO SUPPLEMENTARY GENERAL CONDITIONS:

REVISION:

SC-4.01 CONTRACT TIME

The Contract time shall be 270 calendar days.

--

REVISIONS TO APPENDIX A:

REVISION:

Added Bid Walk Meeting Attendees list (See attachment).

--

CONTRACTOR QUESTIONS:

QUESTION: Will construction water be available for use at the project site?

RESPONSE: The city will provide a fire hydrant with a water meter for the purchase of construction water. The nearest hydrant is located near Plymouth Avenue.

--

QUESTION: What are the extents of shotcrete on the existing ponds?

RESPONSE: The existing pond to be modified contains approximately 2” to 4” thick shotcrete on the east side of the pond.

--

QUESTION: Will the existing pond beds need to be dewatered?

RESPONSE: The existing ponds are currently dry and it is expected to remain dry for the project.

--

QUESTION: Is electrical work include in each bid item?

RESPONSE: Yes, contractor to coordinate and provide price for all electrical work with each bid item.

NOTE: One copy of this Addendum Number 3 shall be signed by the Contractor and must be submitted with the bid as acknowledgement of receipt and the acceptance of this Addendum Number 3.

Prepared by: 

Orfil Muniz, P.E.
A&M Consulting Engineers

January 25, 2021

Date

Accepted by: _____
Contractor (signature)

Date

Project Name: City of Corcoran WWTP Modification & Expansion
Bid Date: 02/08/2021
Bid Time: 11:00 AM

City of Corcoran: http://www.cityofcorcoran.com/government/public_notices.php
Date: 1/21/2021
Engineer's Estimate: \$1,800,000.00

Bid Walk Meeting Attendees

	Company Name	Contact Name	Phone Number	Email
1	Bush Construction	Frank Gouliart	559-584-1575	frank@bushconstruction.net
2	Bill Nelson GEC, Inc.	Mike Emmerich	559-439-1756	estimating@bngec.us.net
3	American Inc.	Ben Crawford	559-749-1608	bcrawford@aminc.com
4	GSE Construction	Marc Saar	925-447-0292	estimating@gseconstruction.com
5	Agee Construction	Alan Diriam	559-326-1335	estimating@ageeconstruction.com
6	Bush Engineering, Inc.	Kannon Robbins	559-584-1575	krobins@busconstruction.net
7	American Paving	Pat Beckwith	559-268-9886	rjenkins@americanpavingco.com
8	Specialty Construction, Inc.	Doug Clay	805-543-1706	sshamblin@specialtyconstruction.com
9	A-C Electric Company	Chris Calhoun	559-679-7257	chriscalhoun@a-electric.com
10	Coombs-Hopkins-Parkson-Aeizen	Brian Villacorta	925-989-6041	brian@chwater.com
11	Lighthouse Electrical	Anthony Olivo	559-895-3200	aoливо@lighthouseelec.com
12	Clark Brothers	Mark Zan	541-941-8442	mzan@clarkbroscinc.com
13	Cal Valley Construction	Andy Brooks	559-804-4494	abrooks@calvalleyconstruction.com
14	Superior Electrical Works	Chris Canfield	559-802-8330	ccanfield@superiorelectrworks.com

Any questions regarding the project during the bidding phase shall be directed to the Project Engineer: Orfil Muniz, PE at 559-429-4747, or e