

City of

**CORCORAN**

Public Works Department

---

FOUNDED 1914

**Addendum #1 for the City of Corcoran  
Water System Meterization Project**

**March 23, 2022**

City of  
**CORCORAN**

Public Works Department

FOUNDED 1914

**Addendum #1:**

**The following additions, deletions, or modifications shall become part of the Contract Documents for the City of Corcoran Water System Meterization Project:**

-----

Contractor Questions:

Q1: Would you please provide us with the City tower and facilities location information referenced in the AMI Systems section of the City of Corcoran Water System Meterization Project RFQ?

A1: An ArcGIS Online map for all City-owned assets and facilities can be found here: <https://arcg.is/0fzrSf>.

--

Q2: Reference page #6, list of 1,952 metered services. Are meter types available for the following sizes: 3" (turbo or compound) and 4"-10" (turbo, compound, or fire service)?

A2: Meter types for all 3" and greater service lines can be found on the City of Corcoran Public Notices page, titled "Commercial Meters", located here: [https://www.cityofcorcoran.com/government/public\\_notices.php](https://www.cityofcorcoran.com/government/public_notices.php).

--

Q3: Do you have a copy of the City's customer service address listings?

A3: A spreadsheet with all of the City's customer service addresses, meter type, and class code can be found on the City of Corcoran Public Notices page, titled "All Customers Metered and Flat", located here: [https://www.cityofcorcoran.com/government/public\\_notices.php](https://www.cityofcorcoran.com/government/public_notices.php).

--

Q4: The RFP stated that this must not exceed 50 pages, but does that include spec sheets, table of contents, warranty info, section dividers, etc.?

A4: No, it does not. Please consider those items separate from the quotation and exclude them from the 50-page limit.

--

Q5: Will the City accept meters made of composite alloy?

A5: No, the City will not accept any composite meters. Bronze and stainless steel are the only meter composition types allowed.