



# TOWN OF CULPEPER

---

## Procurement

400 S Main Street Suite 105

Culpeper, VA 22701

Phone: (540) 829-8242 Fax: (540) 829-8249

May 25, 2023

### ADDENDA NO. 2 TO ALL BIDDERS:

Reference – ITB: PW-23-47001  
Title: Biosolids Disposal  
Subject: Clarifications

A mandatory pre-bid meeting was held on May 24, 2023. Representative(s) from the following vendors attended: Recyc Systems and Synagro

The following clarifications constitute Addendum No. 2. Please acknowledge receipt of this Addendum No. 2, dated May 25, 2023, on the Bidder Information Form where indicated when returning your Bid package or acknowledge if your Bid package has already been mailed. **Failure to acknowledge this addendum may result in your bid being declared non-responsive.**

The following questions were received:

1. Is the contractor permitted to use straw? **Response: YES**
2. What is the storage pad wet ton capacity? **Response: 800**
3. How much notice must be given for the town to coordinate a loader operator? **Response: 24 hours is recommended but there is no requirement.**
4. May the contractor provide a loader operator in the event the town cannot? **Response: NO**
5. Is the town responsible for any damage to the contractors equipment during the loading process? **Response: YES**
6. Is there scales onsite? (How is weight verified, if not) load estimated? **Response: NO, the weight is verified by the capacity of the truck.**
7. Is there a minimum minority participation? **Response: NO**
8. What is the average cake percent solids. **Response: 23%**

All other general terms, conditions and specifications shall remain the same.

---

Lisa Wortman, Procurement Officer