



Addendum No. 5: Dated July 20, 2022 to bidding documents for the Town of Culpeper WWTP Improvements for the Town of Culpeper, Virginia, WW Associates Project No. 221028.00.

From: WW Associates, Inc.

To: All Bidding Document Holders of Record

This addendum forms a part of the bidding documents and modifies the drawing and specifications dated April 29, 2022. Acknowledge receipt of this addendum in the space provided on the bid form. Failure to do so may subject the bidder to disqualification.

DRAWINGS

Drawing C-7 – Equalization Splitter Box, Existing Conditions & Demolition, Plan & Section

Add the following under Demolition Notes: “7. Bypass the main flow to the equalization splitter box during the construction of the sluice gates at no additional cost to the Owner.”

End of Addendum No. 5