



Contact Jaime Fleming, at (616)261-3572 or flemingj@wymingmi.gov for technical questions about this report, or with any water quality questions. Copies are available at City Hall, and the Grandville Public Library. Grandville's City Commission meets the 2nd and 4th Monday of each month, at 7:00 p.m. at Grandville's City Hall. To learn more about the Utilities Department, visit us on the web at www.cityofgrandville.com

Esta publicación contiene información importante sobre el agua que usted bebe diariamente. Si no lo entiende, busque a alguien que se lo traduzca o le explique su contenido. Para más información, llame al (616)530-7389 o visite [página electrónica](http://www.epa.gov/espanol/).



Only Tap Water Delivers



City of Grandville
3195 Wilson Avenue, SW
Grandville, MI 49418

City of Grandville

2018 Water Quality Report



We are pleased to report that your drinking water meets, and often is better than, all state and federal guidelines for safe drinking water.

Included in the details of this water quality report is important information about where your water comes from, what's in it, and how it compares to standards set by regulatory agencies.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. However, the presence of contaminants in drinking water does not necessarily indicate that the drinking water poses a health risk.

Our source for drinking water is Lake Michigan. Rain, groundwater, rivers, and streams feed into Lake Michigan, dissolving naturally occurring minerals and sometimes picking up substances resulting from the presence of animals or from human activity. Some of the substances that can make their way into Lake Michigan are: viruses and bacteria from animal, agricultural, and human activities, salts, metals, pesticides and herbicides, as well as by-products of industrial processes. In order to ensure that tap water is safe to drink, EPA prescribes regulations, called Maximum Contaminant Levels (MCLs) that limit the amount of certain contaminants in your drinking water. Our water source has a moderately high susceptibility to contaminants. For a copy of the most current Source Water Assessment of the water system, please call our office at 616-399-6511.



The U.S. Environmental Protection Agency and the State of Michigan require all community water system suppliers to put the annual water quality report into the hands of their consumers. Rule 63 FR 44511, effective August 19, 1998 requires that all water suppliers shall mail or

otherwise directly deliver one copy of their consumer confidence report to each billing customer.

Definition Key

- AL** Action Level: The concentration of a contaminant which, if exceeded, triggers a treatment or other requirement, which a water system must follow.
- MCL** Maximum Contaminant Level: the highest level of a contaminant that is allowed in drinking water; MCL's are set as close to the MCLG's as feasible using the best available treatment technology.
- MCLG** Maximum Contaminant Level Goal: the level of a contaminant in drinking water below which there is no known or expected risk to health; MCLG's allow for a margin of safety.
- MRDL** Maximum Residual Disinfection Level: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- MRDLG** Maximum Residual Disinfection Level Goal: The level of a drinking water disinfectant below which there is no known or expected risk to health. **MRDLG's do not reflect the benefits to the use of disinfectants to control microbial contaminants.**
- NA** Not applicable
- ND** Not Detected
- NTU** Nephelometric Turbidity Unit: measurements of minute suspended particles, used to judge water clarity.
- ppb** parts per billion or micrograms per liter (ug/l)
- ppm** parts per million or milligrams per liter (mg/l)
- TT** Treatment Technique: a required process, intended to reduce the level of a contaminant in drinking water.



Water Quality Report

Each day, our staff works to ensure the water delivered to your home meets all regulatory requirements and your expectations for safety, reliability and quality. For your protection, your drinking water is tested for many parameters. The table below shows only the substances detected in your water during the calendar year. We are proud to report there were no violations during that time.

2018

REGULATED MONITORING AT THE TREATMENT PLANT

SUBSTANCE	UNITS	Range of Detection	Average Level Found	MCL	MCLG	Samples Exceeding MCL	POSSIBLE SOURCES
Fluoride	ppm	0.48 - 0.80	.67	4	4	0	Additive which promotes strong teeth

SUBSTANCE	UNITS	Level Found	MCL	MCLG	Samples Exceeding MCL	POSSIBLE SOURCE
Turbidity	NTU	.09	TT = 1 NTU	NA	0	Soil runoff and natural sediment

100% of Turbidity sample levels were found to be < 0.3 NTU.

REGULATED CHEMICAL MONITORING IN THE DISTRIBUTION SYSTEM

SUBSTANCE	UNITS	Range	Highest Running Annual Average	MCL	MCLG	Samples Exceeding MCL	POSSIBLE SOURCES
Chlorine Residual	ppm	0.3-1.43	0.9	4	MRDLG=4	0	Used to disinfect drinking water
Haloacetic Acids	ppb	14 - 40	23	60	NA	0	Formed when chlorine is added to water with naturally occurring organic material
Trihalomethanes	ppb	27 - 55	42	80	NA	0	

REGULATED MONITORING AT CUSTOMER'S TAP

Compliance is determined using the 90th percentile, where nine out of ten samples must be below the Action Level. Testing was conducted in 2016.

SUBSTANCE	UNITS	90th Percentile	AL	MCLG	Samples Exceeding AL	POSSIBLE SOURCES
Copper	ppb	41	1300	1300	0	Corrosion of household plumbing system, erosion of natural deposits, micronutrients
Lead	ppb	1.7	15	0	1	

REGULATED BACTERIOLOGICAL MONITORING IN THE DISTRIBUTION SYSTEM

SUBSTANCE	Highest Level Found	MCL	MCLG	DATE	Violation?	POSSIBLE SOURCES
Total Coliform	0.9% of all samples collected in the month of August	5% of samples collected in a month	0	None	No	Naturally present in the environment
Fecal Coliform or E. Coli bacteria	0.08% of all samples collected 1 of 1171 samples		0	None	No	Human or animal fecal waste

UNREGULATED MONITORING

SUBSTANCE	UNITS	Range of Detection	Average Level Found	SOURCE
Hardness	ppm	134 - 154	143	Naturally present due to dissolved calcium and magnesium salt
pH	pH units	7.4 - 7.5	7.5	pH is an important measurement of the acidity or alkalinity of water
Chloride	ppm	18 - 21	19	Naturally present in the environment
Sodium	ppm	9.4 - 10	9.8	Naturally present in the environment

SPECIAL MONITORING

SUBSTANCE	UNITS	Range of Detection	Average Level Found	Comments
Chlorate	ppb	51 - 230	130	Unregulated contaminants are those for which EPA has not established drinking water standards. Monitoring helps EPA to determine where certain substances occur and whether it needs to regulate those substances. Results of monitoring are available upon request.
Chromium	ppb	.2 - .3	.3	
Chromium-6	ppb	.16 - .23	.19	
Molybdenum	ppb	ND - 1.1	.8	
Strontium	ppb	110 - 140	125	
Vanadium	ppb	ND - .4	.24	

Results were gathered from tests performed by the City of Wyoming's certified lab, as well as the State of Michigan's Department of Environmental Quality laboratory and other certified private laboratories. As authorized by the EPA, the State has reduced monitoring requirements for certain contaminants to less often than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year.

If present, elevated levels of lead

can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking.

If you are concerned about lead in your water, you may wish to have your water tested.



Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline at 800-426-4791 or at www.epa.gov/safewater/lead.

Testing is also performed to detect the presence of Cryptosporidium and Giardia, which are protozoan parasites that occur in natural surface waters such as lakes, rivers and streams. Wyoming's water treatment process provides multiple barriers, including clarification, filtration, and disinfection, to lower the risk of these contaminants in finished tap water. Monitoring of treated water samples yielded a 100% removal rate, highlighting the effectiveness of the treatment system in microscopic particle removal. For information on microbiological testing, contact the Wyoming laboratory at 616-261-3572.

For more information about contaminants and potential health effects, call the EPA's Safe Drinking Water Hotline: (800) 426-4971 or visit www.epa.gov/safewater/dwhealth