



Contact Jaime Fleming, at (616)261-3572 or flemingj@wyomingmi.gov for technical questions about this report, or with any water quality questions. Copies are available at City Hall, and the Grandville Public Library. Grandville's City Commission meets the 2nd and 4th Monday of each month, at 7:00 p.m. at Grandville's City Hall. To learn more about the Utilities Department, visit us on the web at www.cityofgrandville.com

Esta publicación contiene información importante sobre el agua que usted bebe diariamente. Si no lo entiende, busque a alguien que se lo traduzca o le explique su contenido. Para mas información, llame al (616)530-7389 o visite página electrónica. www.epa.gov/espanol/



Number of Service Connections by Line Material

Likely Contains Lead	Unknown Likely Does Not Contain Lead	Material(s) Unknown
0	250	0
Contains Neither Lead nor Galvanized Previously Connected to Lead		Total**
5,147		5,397

**The total number should equal the total number of potable water service lines in your water supply (residential, commercial, industrial, other)

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER Reporting Requirements Not Met by the City of Grandville
We are required to report our results of Water Quality Parameters (WQP) of your drinking water on a regular basis. During the reporting months of July 2019 – September 2019 and October 2019 – December 2019, we did not report our results to the Michigan Department of Environment, Great Lakes, and Energy (EGLE). This is a reporting violation only and poses no threat to your supply's water.

Even though this is not an emergency, as our customers, you have a right to know what happened and what we did to correct the situation.

Below are the WQP analytes that we test for. Samples are taken every quarter and there are ten samples sites throughout the city.

pH alkalinity calcium conductivity temperature sulfate chloride orthophosphate

What happened? What is being done? We failed to send in our results for the monitoring period of July 2019/September 2019 and October 2019/ December 2019. The results have now been reported to EGLE for these periods.

For more information, please contact: Charles Sundblad, Director of Public Works 616-538-1990
This notice is being sent to you by: City of Grandville Public Works

* WQP are a group of analytes that are indicators of corrosivity. They include pH, alkalinity, calcium, conductivity, temperature, sulfate, chloride, and orthophosphate.

City of Grandville

2019 Water Quality Report



We are pleased to report that your drinking water meets, and often is better than, all state and federal guidelines for safe drinking water.

Included in the details of this water quality report is important information about where your water comes from, what's in it, and how it compares to standards set by regulatory agencies.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. However, the presence of contaminants in drinking water does not necessarily indicate that the drinking water poses a health risk.

Our source for drinking water is Lake Michigan. Rain, groundwater, rivers, and streams feed into Lake Michigan, dissolving naturally occurring minerals and sometimes picking up substances resulting from the presence of animals or from human activity. Some of the substances that can make their way into Lake Michigan are: viruses and bacteria from animal, agricultural, and human activities, salts, metals, pesticides and herbicides, as well as by-products of industrial processes. In order to ensure that tap water is safe to drink, EPA prescribes regulations, called Maximum Contaminant Levels (MCLs) that limit the amount of certain contaminants in your drinking water. Our water source has a moderately high susceptibility to contaminants. For a copy of the most current Source Water Assessment of the water system, please call our office at 616-399-6511.



The U.S. Environmental Protection Agency and the State of Michigan require all community water system suppliers to put the annual water quality report into the hands of their consumers. Rule 63 FR 44511, effective August 19, 1998 requires that all water suppliers shall mail or

otherwise directly deliver one copy of their consumer confidence report to each billing customer.

Definition Key

- AL** Action Level: The concentration of a contaminant which, if exceeded, triggers a treatment or other requirement, which a water system must follow.
- MCL** Maximum Contaminant Level: the highest level of a contaminant that is allowed in drinking water; MCL's are set as close to the MCLG's as feasible using the best available treatment technology.
- MCLG** Maximum Contaminant Level Goal: the level of a contaminant in drinking water below which there is no known or expected risk to health; MCLG's allow for a margin of safety.
- MRDL** Maximum Residual Disinfection Level: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- MRDLG** Maximum Residual Disinfection Level Goal: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLG's do not reflect the benefits to the use of disinfectants to control microbial contaminants.
- NA** Not applicable
- ND** Not Detected
- NTU** Nephelometric Turbidity Unit: measurements of minute suspended particles, used to judge water clarity.
- ppb** parts per billion or micrograms per liter (ug/l)
- ppm** parts per million or milligrams per liter (mg/l)
- TT** Treatment Technique: a required process, intended to reduce the level of a contaminant in drinking water.



Water Quality Report

Each day, our staff works to ensure the water delivered to your home meets all regulatory requirements and your expectations for safety, reliability and quality. For your protection, your drinking water is tested for many parameters. The table below shows only the substances detected in your water during the calendar year. We are proud to report there were no violations during that time.

2019

REGULATED MONITORING AT THE TREATMENT PLANT							
SUBSTANCE	UNITS	Range of Detection	Average Level Found	MCL	MCLG	Samples Exceeding MCL	POSSIBLE SOURCES

Fluoride	ppm	0.57 - 1.1	.66	4	4	0	Additive which promotes strong teeth
----------	-----	------------	-----	---	---	---	--------------------------------------

SUBSTANCE	UNITS	Level Found	MCL	MCLG	Samples Exceeding MCL	POSSIBLE SOURCE
-----------	-------	-------------	-----	------	-----------------------	-----------------

Turbidity	NTU	.03	TT = 1 NTU	NA	0	Soil runoff and natural sediment
-----------	-----	-----	------------	----	---	----------------------------------

100% of Turbidity sample levels were found to be < 0.3 NTU.

REGULATED CHEMICAL MONITORING IN THE DISTRIBUTION SYSTEM							
SUBSTANCE	UNITS	Range	Highest Running Annual Average	MCL	MCLG	Samples Exceeding MCL	POSSIBLE SOURCES
Chlorine Residual	ppm	0.2 - 1.34	0.8	4	MRDLG=4	0	Used to disinfect drinking water
Haloacetic Acids	ppb	10 - 31	22	60	NA	0	Formed when chlorine is added to water with naturally occurring organic material
Trihalomethanes	ppb	21 - 46	37	80	NA	0	

REGULATED MONITORING AT CUSTOMER'S TAP						Testing was conducted in 2019.
Compliance is determined using the 90th percentile, where nine out of ten samples must be below the Action Level.						
SUBSTANCE	UNITS	90th Percentile	AL	MCLG	Samples Exceeding AL	POSSIBLE SOURCES
Copper	ppb	100	1300	1300	0	Corrosion of household plumbing system, erosion of natural deposits, micronutrients
Lead	ppb	2	15	0	0	

REGULATED BACTERIOLOGICAL MONITORING IN THE DISTRIBUTION SYSTEM						
SUBSTANCE	Highest Level Found	MCL	MCLG	DATE	Violation?	POSSIBLE SOURCES
Total Coliform	0.9% of all samples collected in the month of August	5% of samples collected in a month	0	None	No	Naturally present in the environment
Fecal Coliform or E. Coli bacteria	0.08% of all samples collected 1 of 1171 samples		0	None	No	Human or animal fecal waste

UNREGULATED MONITORING				
SUBSTANCE	UNITS	Range of Detection	Average Level Found	SOURCE
Hardness	ppm	131 - 172	145	Naturally present due to dissolved calcium and magnesium salt
pH	pH units	7.4 - 7.5	7.5	pH is an important measurement of the acidity or alkalinity of water
Chloride	ppm	14 - 19	16	Naturally present in the environment
Sodium	ppm	9.6 - 13	11	Naturally present in the environment

SPECIAL MONITORING				
SUBSTANCE	UNITS	Range of Detection	Average Level Found	Comments
Chlorate	ppb	51 - 230	130	Unregulated contaminants are those for which EPA has not established drinking water standards. Monitoring helps EPA to determine where certain substances occur and whether it needs to regulate those substances. Results of monitoring are available upon request.
Chromium	ppb	.2 - .3	.3	
Chromium-6	ppb	.16 - .23	.19	
Molybdenum	ppb	ND - 1.1	.8	
Strontium	ppb	110 - 140	125	
Vanadium	ppb	ND - .4	.24	

Results were gathered from tests performed by the City of Wyoming's certified lab, as well as the State of Michigan's Department of Environmental Quality laboratory and other certified private laboratories. As authorized by the EPA, the State has reduced monitoring requirements for certain contaminants to less often than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking.

If you are concerned about lead in your water, you may wish to have your water tested.



Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline at 800-426-4791 or at www.epa.gov/safewater/lead.

Testing is also performed to detect the presence of Cryptosporidium and Giardia, which are protozoan parasites that occur in natural surface waters such as lakes, rivers and streams. Wyoming's water treatment process provides multiple barriers, including clarification, filtration, and disinfection, to lower the risk of these contaminants in finished tap water. Monitoring of treated water samples yielded a 100% removal rate, highlighting the effectiveness of the treatment system in microscopic particle removal. For information on microbiological testing, contact the Wyoming laboratory at 616-261-3572.

For more information about contaminants and potential health effects, call the EPA's Safe Drinking Water Hotline: (800) 426-4971 or visit www.epa.gov/safewater/dwhealth