



**NOTE:**

- 1- ALTERNATELY, THE OPEN END OF THE PIPE MAY BE EXTENDED TO AS LITTLE AS 1 FOOT ABOVE THE TOP OF THE PIPE IF THE VALVE CHAMBER IS NOT SUBJECT TO FLOODING, OR IF IT MEETS THE REQUIREMENTS OF UAC R309-550-6(7).

**GRANTSVILLE CITY  
AIR RELEASE VALVE MANHOLE DETAIL**