



**ADDENDUM NO. 1  
DOWNTOWN PARKING LOT REHABILITATION  
401-703-975.220**

January 4, 2023

**To:** All Plan Holders.

**Notice:** This addendum to the plans and specifications is to add to or supersede all pertinent information in the original plans and specifications. The amendments made herein shall become part of the bidding documents as originally issued.

**Bid Date is unchanged.** Tuesday, January 10, 2023 at 2:00 p.m.

**Clarifications to Project Scope:**

1. The City will be responsible for all testing of materials.
2. The thickness of existing HMA surface is 2-2½". An additional ½-1" of aggregate base will need to be removed to accommodate the new 3" HMA thickness. The cost for the additional removal can be accounted for in the Cold Milling or Aggregate Base Conditioning pay items, which are both paid for by square yard.
3. Heavy Duty Pavement applies to a 10'x10' area surrounding adjusted structures.
4. HMA shall be laid in two lifts.
5. The HMA top course shall be a commercial (not MDOT) grade of 5E1 at 165 lbs/syd and level course shall be 4E1 at 165 lbs.syd.
6. Millings from removals can be retained by the Contractor or left with the City at the preference of the Contractor. If left with the City, they shall be deposited as directed either at 218 E. Fairplains Street (1 mile) or 1150 Owen Mumaw Drive (2.32 miles)
7. Parking lots do not have official addresses, but for location purposes the following can be used:

LOT 1	112 W. Benton
LOT 2	111 W. Cass
LOT 3	210 S. Franklin
LOT 4	114 S. Franklin
LOT 5	109 S. Clay
LOT 6	209 S. Clay
LOT 7	119 E. Cass
LOT 8	308 S. Clay
LOT 9	301 S. Franklin

**Please acknowledge receipt of this Addendum on page 14 of the Bid Form.**