

# PUBLIC NOTIFICATION

## Thomas Mackey Water Treatment Plant Municipal Customers

Bacliff MUD	James Wistinghausen	bacliffmud@comcast.net	Mike Morgan	mike-bmud@outlook.com
Bayview MUD	Richard Evans	richardtevens@bayviewmud.com	Bayview MUD	bayviewmud@bayviewmud.com
City of Galveston	Dennis Stark	destark@galvestontx.gov		
City of Hitchcock	Marie Gelles	mgelles@cityofhitchcock.org	Leroy Thomas	lthomas@cityofhitchcock.org
City of La Marque	Rick Sailler	rsailler@cityoflamarque.org		
City of League City	Jody Hooks	jody.hooks@leaguecitytx.gov		
City of Texas City	Corbin Ballast	cballast@texascitytx.gov	Jason Baecker	jbaecker@texascitytx.gov
GC FWSO No 6 (Tiki Island)	Steve Jefferson	gcfwsd_6@gcfwsd6.com		
GC MUD No 12 (Bayou Vista)	Eric Moeller	ehmoeller@me.com		
GC WCID No 1 (Dickinson)	Ivan Langford	ilangford@wcid1.com	Keith Morgan	kmorgan@wcid1.com
GC WCID No 8 (Santa Fe)	James Newman	water65@comcast.net	Dee Ann Hedgpeth	gcwcid@comcast.net
GC WCID No 12 (Kemah)	Johnny Bellamy	jbellamy@mdswater.com		
San Leon MUD	Ken Keller	keller42@slmud.org	San Leon MUD	slmud1@slmud.org

Distribution List Updated December 5th, 2023

**FROM: Gulf Coast Water Authority's Thomas Mackey Water Treatment Plant Manager - Tony Garcia**

Office Phone: 832.645.1281

Cell Phone: 281.967.1917

Fax: 409.943.4522

Email: tgarcia@gcwatx.gov

### NOTICE OF COMPLIANCE for the TCEQ MONTHLY REPORT

Date: Monday, June 10, 2024

For the Month of: May-2024

PUBLIC NOTIFICATION			
TREATMENT TECHNIQUE VIOLATIONS	YES / NO	If YES, date when notice was given to:	
		COMMISSION	CUSTOMERS
Were more than 5% of the turbidity readings above the acceptable level?	NO		
Were there any days with the turbidity readings above 1.0 NTU?	NO		
Were there any days with the turbidity readings above 5.0 NTU?	NO		
Were there any periods where the plant failed to meet the CT requirements for more than 4.0 consecutive hours?	NO		
Were there any periods when the residuals leaving the plant fell below the acceptable level for more than 4.0 consecutive hours?	NO		
Were more than 5% of the residuals in the distribution system below the acceptable level for two months in a row?	NO		