



WATER QUALITY TEST RESULTS

Project Name: _____			
Project Number: _____			
Analyte	Date:	Safe Drinking Water Act	Drinking Standard
		MCL ⁽¹⁾	
	Lab Results		
Antimony		0.006 mg/L ⁽¹⁾	Primary
Arsenic		0.01 mg/L ⁽¹⁾	Primary
Barium		2.0 mg/L ⁽¹⁾	Primary
Beryllium		0.004 mg/L ⁽¹⁾	Primary
Cadmium		0.005 mg/L ⁽¹⁾	Primary
Chromium		0.1 mg/L ⁽¹⁾	Primary
Copper		1.3 mg/L ⁽¹⁾	Primary
Fluoride		4.0 mg/L ⁽¹⁾	Primary
Lead		0.015 mg/L ⁽¹⁾	Primary
Mercury		0.002 mg/L ⁽¹⁾	Primary
Nitrate (as Nitrogen, NO ₃ -N)		10.0 mg/L ⁽¹⁾	Primary
Nitrate (NO ₃)		44.3 mg/L ⁽¹⁾	Primary
Nitrite (as Nitrogen, NO ₂ -N)		1.0 mg/L ⁽¹⁾	Primary
Nitrite (NO ₂)		3.3 mg/L ⁽¹⁾	Primary
Selenium		0.05 mg/L ⁽¹⁾	Primary
Thallium		0.002 mg/L ⁽¹⁾	Primary
Microbiology			
Total Coliform		Presence	Primary
E.Coli		Presence	Primary

Notes:

mg/L = milligrams per Liter; NTU = Nephelometric Turbidity Units, ND = Not Detected

Footnotes:

(1) SDWA NPDWR MCL= Safe Drinking Water Act National Primary Drinking Water Regulations Maximum Contaminant Level. These are legally enforceable standards that apply to public drinking water systems. Primary standards protect public health by limiting the levels of contaminants in drinking water.