

INSPECTIONS FOR NEW STRUCTURES AND ADDITIONS

1. TEMPORARY ELECTRICAL SERVICE POLE
2. FOOTING INSPECTION-FOUNDATION READY FOR POURING
3. OPEN FLOOR IF CRAWL SPACE PRIOR TO FLOOR SHEATHING, PLUMBING IN SLAB
IF SLAB HOME
4. IF SLAB HOME A BUILDING SLAB INSPECTION IS REQUIRED ALSO
5. ROUGH IN INSPECTION-UNIT FRAMED PRIOR TO INSTALLATION OF INSIDE WALL
COVERING AND INSULATION; ELECTRICAL, HVAC AND PLUMBING IN PLACE;
PRESSURE TESTING ON SUPPLY LINES AND DRAIN TEST ON ALL DRAIN LINES,
TUBS AND SHOWERS (WITH A 10' HEAD OF WATER ABOVE THE HIGHEST
FIXTURES)
6. TEMPORARY POWER. ALL DEVICES SET OR SAFEGUARDED TO PREVENT
ACCIDENTAL CONTACT.
7. FINAL INSPECTION-HOUSE SHOULD BE MOVE IN READY. BLOWER DOOR AND DUCT
BLASTER TEST RESULTS SHOULD ALSO BE PRESENTED ON ALL NEW HOMES.