_____	☐	Doors and windows must have good weather stripping or storm window or storm door. They must also open fully and easily. All glass panes must be unbroken and caulked correctly.	410.500, 501
_____	☐	Roof	410.500
_____	☐	Chimneys and other structural elements	410.500
_____	☐	Staircases must be stable with a safe handrail.	410.500, 503(A) and (B)
_____	☐	Every porch, balcony or roof over 30 inches above the ground must have a wall or guardrail that is at least 3 feet high.	410.503(C)

Space

_____	☐	Every dwelling unit must have at least 150 square feet of floor space for the first occupant and 100 square feet for each additional occupant. Add up all the floor space in "habitable rooms" to get the number of square feet in your unit. "Habitable room" means any room to be used for living, sleeping, cooking, or eating. Do not include your pantry, bathrooms, laundry room, halls, or storage spaces.	410.400(A)
_____	☐	Every bedroom must have at least 70 square feet of floor space if only one person sleeps there. If more than one person is sleeping in the room, it must have 50 square feet of floor space for each person.	410.400(B)