

Shade Tree Review

1100-1118 South Avenue

PB 2022-27

Good Afternoon,

I have reviewed the plans from Anderson Consulting Services LLC for the project at 1100-1118 South Avenue. The Landscaping Plan, found on SP-5 and dated for 11/21/22 meets the requirements as outlined in Section 17:9-49C of the ordinance, which reads: Shade trees shall be planted at intervals of forty (40) feet along a right-of-way and a minimum of three and one-half (3.5) feet inside the sidewalk.

Thank you for your consideration.

Respectfully,

Daniel White