



The Town of Plainfield  
8 Community Avenue  
Plainfield, CT 06374

Costantino Galasso  
Fire Marshal  
PH. (860) 230-3013  
FAX (860) 230-3033  
Email: [cgalasso@plainfieldct.org](mailto:cgalasso@plainfieldct.org)

PLAINFIELD – CENTRAL VILLAGE – MOOSUP – WAUREGAN

## Office of the Fire Marshal FOOD TRUCK PERMIT APPLICATION

Permission shall be granted to the below named party to operate a Food Truck, per the constraints of this permit, and the International Fire Code.

License Plate # \_\_\_\_\_

DL# \_\_\_\_\_

VIN# \_\_\_\_\_

PERMIT NUMBER: \_\_\_\_\_

DATE OF ISSUE: \_\_\_\_\_

EXPIRATION DATE: \_\_\_\_\_

Fire Marshal: \_\_\_\_\_

For Official Use Only

### Responsible Party

Responsible Party Name: \_\_\_\_\_

Responsible Party Address: \_\_\_\_\_  
Street Address

\_\_\_\_\_  
City State Zip

Emergency Contact: \_\_\_\_\_

Phone Number: \_\_\_\_\_ Mobile/Cell: \_\_\_\_\_

### Food Truck Name

Food Truck/Business Name: \_\_\_\_\_

Vehicle Type, Make, Model, Year: \_\_\_\_\_

**A list of operational requirements shall be given to the applicant. Any inspection shall be conducted on the day of the event.**

**This permit shall be clearly posted in a conspicuous place, or as mandated by the Fire Marshal.**

# FOOD TRUCK OPERATIONAL REQUIREMENTS

1. Provide appropriate waste receptacles at the site of the unit and remove all litter, debris, and other waste attributable to the vendor on a daily basis.
2. Shall not be parked, situated or operated in a manner that restricts or blocks emergency vehicle apparatus access.
3. Shall not be parked, situated or operated in a manner that restricts or blocks fire hydrants, fire lanes or other fire protection equipment or access.
4. Comply with the Town of Plainfield applicable ordinances.
5. Comply with all applicable federal and state regulations.
6. Not represent the granting of a permit under this chapter as an endorsement by the Town of Plainfield.
7. Cooking operations in which grease laden vapors are or can be created, shall be provided with a Type I hood and fire suppression system.
8. Fire suppression system shall be inspected by a licensed company annually.
9. A minimum of 1 K- Class fire extinguisher shall be provided if the potential of grease laden vapors can be produced.
10. A minimum of 1 2A-10BC fire extinguisher shall be provided.
11. Propane cylinders shall be secured to the vehicle and installed in accordance with NFPA 58.
12. All temporary electrical shall comply with the provisions of applicable codes and any other applicable city ordinances or codes.