

64. **AT A SPECIAL MEETING OF THE WAUREGAN FIRE DISTRICT
HELD ON DECEMBER 15,1978, THE FOLLOWING ORDINANCE WAS
ADOPTED:**

ORDINANCE

Be it ordained by the President and directors of the Wauregan Fire District That:

SECTION 1. Definition

(a) DEVELOPMENT: Any single family homes erected in groups of more than two (2) by the same builders, contractors, person or persons, corporation, or other legal entities within one thousand (1,000) feet of each other (known as housing projects):

Also:

Apartment projects consisting of two (2) or more apartments per dwelling or building and two (2) or more buildings within one thousand (1,000) feet of each other:

Also:

Commercial establishments known as shopping centers consisting of two (2) or more stores or units within two thousand five hundred (2,500) feet of each other:

Also:

All industrial developments no matter the size or location:

Also:

All gas and fuel stations or depots:

Also:

Medical Facilities:

Also:

Schools:

Also:

Convalescent homes, and rest homes.

SECTION 2. If any development and/or project listed in Section One above is constructed within two thousand five hundred (2,500) feet of any existing water main, said water main is to be extended to said development and/or project by means of a pipe having a minimum diameter of ten (10) inches which pipes shall be installed along/and/or in all the streets or roads of said project.

SECTION 3. Hydrants having a minimum diameter of eight (8) inches will be installed on water mains having a diameter of ten (10) inches. These hydrants shall be situated or placed not less than three (3) feet and no more than eight (8) feet from the edge of the street pavement. Said hydrants shall be installed not more than five hundred (500) feet apart along the ten (10) inch water mains, except that in the case of shopping centers and industrial buildings complexes in which case ten (10) inch diameter water mains will be installed in the form of a loop around the perimeter of said shopping center or industrial building complex. In addition, hydrants having a diameter of eight (8) inches will be installed on the ten (10) inch water mains around the loop no more than five hundred (500) feet apart and no less than one hundred (100) feet and no more than two hundred (200) feet from any building.

SECTION 4. In addition to the requirements stated in Sections Two and Three any development or project shall include the following:

- a. a road that is suitably paved
- b. a suitably paved parking lot or right of way for ingress and egress by fire apparatus which shall be maintained and kept clear of ice and snow during the winter season.
- c. all hydrants will be situated no less than three (3) and no more than eight (8) feet from the edge of the paved parking lot or right of way.

SECTION 5. Specifications

All hydrants will be a minimum of eight (8) inches in diameter. They shall include two (2) and one half (2 ½) inch discharge spuds and one (1) four and one half (4 ½) inch steamer connection.

All threading will be of the type that is considered nationally standard.

All steamer connections will face the street, parking lot or access road, as the case may be, for purpose of access road, as the case may be, for purpose of access by fire apparatus.

SECTION 6. This Ordinance shall become effective on December 15, 1978.

BY ORDER OF THE PRESIDENT AND DIRECTORS
JULIAN L. BOUCHER
President & Chairman

Signed: PATRICIA CARROLL
Town Clerk of Plainfield