



TOWN OF SOUTHINGTON FIRE MARSHAL'S OFFICE

Community Risk Reduction
310 North Main St., Southington, CT 06489
(860) 621-3202



SITE PLAN REVIEW STATUS

DATE: 4/4/2023

TO: Town Planner

FROM: Fire Marshal's Office

RE: Plan # SPR#1865 Fire Plan # 23-056

The plans submitted to our office for review have been:

Approved Rejected

Address of Property: 87,149,185 Aircraft Rd.

Comments:

If fire area exceeds 12,000 sqft or fire area for vehicles exceeds 5,000 sqft then sprinkler system will be required.

J. Roy