



**TOWN OF SOUTHINGTON
FIRE MARSHAL'S OFFICE**

Community Risk Reduction
310 North Main St., Southington, CT 06489
(860) 621-3202



SITE PLAN REVIEW STATUS

DATE: 4/11/23

TO: Town Planner

FROM: Fire Marshal's Office

RE: Plan # SPR-1866

Fire Plan # 23-074

The plans submitted to our office for review have been:

Approved

Rejected

Address of Property: 1615 West St

Comments:

CAVA - Addition building. This addition
will increase the square footage of the
entire building including the existing building
Building plan to follow will need to include
possible new fire protection systems if required
by increase of total Fire Area.