

From: Ron Wolff <ron@wolffengineering.com>

Sent: Tuesday, May 16, 2023 7:50 AM

To: Jim Grappone <grapponej@southington.org>

Cc: David Lavallee <lavalleed@southington.org>; Mandy Taylor <taylorm@southington.org>; Jennifer Montone <montonej@southington.org>; Kellyc@bycarrier.com; Eric Carrier <carrierexc@gmail.com>

Subject: Re: SPU # 677 #38 Lavender Lane

EXTERNAL EMAIL: This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Good morning Jim,

Attached to this email are updated plans.

The following is a response to your review comments:

- A callout for a cleanout/inspection port and a detail for the underground storage chambers has been added to the plans.
- A detail for the proposed yard drain has been added to the plans. The yard drain is not a drywell, it collects runoff from the low point between the house and garage and directs it to the underground storage chambers.
- The yard drain discharges into the leader drain collector pipe around the house.

Sincerely,

Ronald Wolff, P.E.

WOLFF ENGINEERING

Cornerstone Professional Park, Suite C101

39 Sherman Hill Road

Woodbury, CT 06798

Email: ron@wolffengineering.com

web:

<https://link.edgepilot.com/s/c775389a/k4ni7I9tZkCd1IBOMK1nAA?u=http://www.wolffengineering.com/>

Tel. 203.263.7447

Fax. 203.263.0060