



TOWN OF SOUTHINGTON FIRE MARSHAL'S OFFICE

Community Risk Reduction
310 North Main St., Southington, CT 06489
(860) 621-3202



SITE PLAN REVIEW STATUS

DATE: 9/26/22

TO: Town Planner

FROM: Fire Marshal's Office

RE: Plan # SPR 1855

Fire Plan # 22-233

The plans submitted to our office for review have been:

Approved

Rejected

Address of Property: 1908 West St

Comments:

FDC Connection will need to be shown
on building plans. Also underground
and above ground sprinkler certificates
must be submitted for CO approval.

9/22/22