



**TO:** All Contractors

**FROM:** Cesar Rangel, P.E., Public Works Director / City Engineer

**DATE:** April 18, 2024

**SUBJECT:** **ADDENDUM NO. 2** to the Citywide Landscaping Maintenance Services RFP

---

This Addendum No. 2 is being issued for the Citywide Landscaping Maintenance Services Request for Proposal ("RFP").

**The intent of this Addendum No. 1 is to include the following revisions, additions, and/or deletions shall hereby be made a part of the RFP documents.**

Listed below are the questions / inquiries received and the City's Responses:

1. Will the successful bidder be able to keep a 40-yard green waste container anywhere in the City?

**Response: No. Contractor will be required to remove green waste from the sites. CR&R trash dumpsite is within City limits.**

2. Will the successful bidder have an opportunity to inspect irrigation systems and provide an estimate prior to assuming full responsibility?

**Response: No.**

3. Who is the current contractor?

**Response: Venco Western, Inc.**

4. What is the current monthly contract amount?

**Response: \$24,863 per month for landscape maintenance. Does not include backflow testing.**

5. Are there any restrictions on chemicals to be used within the City?

**Response: No restrictions, as long as the City is in compliance with Federal, State, and local guidelines and restrictions.**

6. How many backflows require annual testing?

**Response: Backflow device list is provided in Attachment A.**


7. Refer to Exhibit A / Scope of Service / Landscape Maintenance on page 33 and 34. Please provide the type of mulch required?

**Response: Playground mulch, engineered wood fiber (EWF). NO rubber mulch.**

For any further information or clarification needed, please contact Scott Jensen via email at [SJensen@StantonCA.gov](mailto:SJensen@StantonCA.gov).

Confirmation of receipt of all addenda is part of the Proposal documents. Failure to acknowledge receipt of all addenda may cause a bid to be deemed non-responsive.

By:

A handwritten signature in blue ink, appearing to read "Cesar Rangel", is written over a horizontal line.

Cesar Rangel, P.E.  
Public Works Director / City Engineer

Attachments:

(A) Back Flow Device Inventory

PREM_LOC	LAST_TEST_DT	TEST_M ONTH	ITEM_ID	BADGE_NBR	MTR_SERIAL_NBR	DESCR	BFA LOCATION
10660 WESTERN STANTON, CA 90680-2249	2/20/24	01/01	9434316948	B043930	8408748	Reduced Pressure Wilkins 2" Backflow Assembly	15' from meter behind fence.
10660 WESTERN FP STANTON, CA 90680	3/18/24	01/01	2392455870	23888	11247352	Double Check Watts 3/4" Backflow Assembly	FP Bypass assembly
10660 WESTERN IRR STANTON, CA 90680	3/18/24	01/01	9827025375	A1509100725	53522639	Reduced Pressure Febco 3" Backflow Assembly	SW corner of parking lot
10660 WESTERN FP STANTON, CA 90680	2/20/24	01/01	2113971013	856930315	11247352	Double Check Detector Assembly Ames 6" Backflow Assembly	Front - FP
8100 PACIFIC ST FP STANTON, CA 90680	3/18/24	01/01	9842000000	H011057	33547621	Double Check Febco 3/4" Backflow Assembly	N side of building on Pacific
11432 BEACH BLVD IRR STANTON, CA 90680	3/18/24	01/01	4114520026	J033345	10013694	Reduced Pressure Febco 1 1/2" Backflow Assembly	median, NO Orangewood
7800 KATELLA FP STANTON, CA 90680-3123	2/21/24	01/01	0226887974	HC64887	20616702	Double Check Wilkins 3/4" Backflow Assembly	BYPASS ON 6#1716F-NW SIDE BLDG.
7800 KATELLA STANTON, CA 90680-3123	2/20/24	01/01	9974636605	J046279	211103638	Reduced Pressure Febco 2" Backflow Assembly	Stanton PK, S/ Comm Blding by parking structure
8100 PACIFIC ST FP STANTON, CA 90680	2/21/24	01/01	0942000000	N0710010724	33547621	Double Check Detector Assembly Febco 8" Backflow Assembly	
11822 SANTA PAULA & IRR STANTON, CA 90680	2/20/24	01/01	6522000000	H24062	232706570	Reduced Pressure Febco 1" Backflow Assembly	ON SANTA PAULA FOR COMMUNITY SERVICE CENTER REAR OF BUILDING
11100 CEDAR STANTON, CA 90680	2/20/24	01/01	8002000000	J021446	8216811	Reduced Pressure Febco 2" Backflow Assembly	ORANGE CTY SHERRIFF
11632 BEACH BLVD-IRR STANTON, CA 90680	2/21/24	01/01	0202000000	A251323	8398750	Reduced Pressure Febco 1" Backflow Assembly	MEDIAN, SO ORANGEWOOD, #11

8741 LOLA IRR STANTON, CA 90680	2/20/24	01/01	520200000	L2927	20012831	Reduced Pressure Wilkins 4" Backflow Assembly	HOLLENBECK PARK
8181 CHAPMAN AVE IRR STANTON, CA 90680	7/7/23	04/01	1288949915	J005395	222040556	Reduced Pressure Febco 1" Backflow Assembly	BY SIDEWALK IN CAGE
7544 KATELLA IRR STANTON, CA 90680	2/21/24	01/01	2654060612	3656723	9053253	Reduced Pressure Wilkins 2" Backflow Assembly	Median E of Western
8100 PACIFIC ST IRR STANTON, CA 90680	2/21/24	01/01	2942000000	J051868	9847295	Reduced Pressure Febco 1" Backflow Assembly	N side of Building on Pacific
10560 BEACH BLVD IRR STANTON, CA 90680	2/21/24	01/01	9939619208	4715538	8398755	Reduced Pressure Wilkins 1" Backflow Assembly	Median on Main
10972 ROSE IRR STANTON, CA 90680	2/20/24	01/01	5945545822	J016390	8404922	Reduced Pressure Febco 1 1/2" Backflow Assembly	In locked cage-alley @ Rose & Katella
7322 KATELLA IRR STANTON, CA 90680	2/15/23	01/01	7006077044	ACC2720	9053257	Reduced Pressure Wilkins 2" Backflow Assembly	Median
11151 BEACH BLVD IRR STANTON, CA 90680	3/18/24	01/01	2136176828	J033324	8869933	Reduced Pressure Febco 1 1/2" Backflow Assembly	Median S/O Katella
11100 CEDAR FP STANTON, CA 90680	2/21/24	01/01	3212000000	3122289	10013689	Double Check Wilkins 3/4" Backflow Assembly	
7800 KATELLA IRR STANTON, CA 90680-3123	2/21/24	01/01	3330584439	H12759	17371591	Reduced Pressure Febco 1 1/4" Backflow Assembly	CITY HALL BLDG SS
12640 BEACH BLVD IRR STANTON, CA 90680	2/21/24	01/01	2592968777	385574	10020412	Reduced Pressure Wilkins 1" Backflow Assembly	Median S/O Lampson
8312 BRIARWOOD ST IRR STANTON, CA 90680	2/20/24	01/01	9610517894	4053484	9053170	Reduced Pressure Wilkins 2" Backflow Assembly	
10350 FERN STANTON, CA 90680	9/8/23	04/01	5690968822	2230917	8926941	Reduced Pressure Wilkins 2" Backflow Assembly	ON FERN AT HARRY M DOTSON PARK IN CAGE