

2022 Consumer Confidence Report (CCR) Certification Form

Water System Name: Stokes County Water and Sewer Authority

Water System No.: NC0285025 Report Year: 2022 Population Served: 420

The Community Water System (CWS) named above hereby confirms that all provisions under 40 CFR parts 141 and 142 requiring the development of, distribution of, and notification of a consumer confidence report have been executed. Further, the CWS certifies the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the primacy agency by their NC certified laboratory. In addition, if this report is being used to meet Tier 3 Public Notification requirements, as denoted by the checked box below, the CWS certifies that public notification has been provided to its consumers in accordance with the requirements of 40 CFR 141.204(d).

Certified by: Name: Stewart Easter

Title: Public Works Director

Signature: 

Phone #: 743-216-0432

Delivery Achieved Date: 6/15/2023

Date Reported to State: 6/15/2023

☐ The CCR includes the mandated Tier 3 Public Notice for a monitoring/reporting violation (check box, if yes).

Check **all** methods used for distribution (see instructions on back for delivery requirements and methods):

☐ Paper copy to all ☐ US Mail ☐ Hand Delivery

☐ Notification of availability of paper copy (Provide a copy of the notice.)

Notification Method _____ (i.e., US Mail, door hanger)

☒ Notification of CCR URL (must be direct URL):

<https://www.co.stokes.nc.us/Public%20Works/Documents/SCWA2022.pdf>

☐ _____

Notification Method On Bill _____ (i.e., on bill, bill stuffer, separate mailing, email)

☐ Direct email delivery of CCR ☐ Attached ☐ Embedded

Notification Method _____ (i.e., on bill, bill stuffer, separate mailing)

☐ Newspaper (attach copy) Name of Paper? _____ Date Published: _____

Notification Method _____ (i.e., on bill, bill stuffer, separate mailing, email)

☐ "Good faith" efforts (in addition to one of the above required methods) were used to reach non-bill paying consumers such as industry employees, apartment tenants, etc. Extra efforts included the following methods:

☒ posting the CCR on the Internet at URL:

<https://www.co.stokes.nc.us/Public%20Works/Documents/SCWA2022.pdf>

☐

☐ mailing the CCR to postal patrons within the service area

☐ advertising the availability of the CCR in news media (attach copy of announcement)

☐ publication of the CCR in local newspaper (attach copy of newspaper)

☐ posting the CCR in public places such as: (attach list if needed) _____

☐ delivering multiple copies to single bill addresses serving several persons such as: apartments,

The certification form on the previous page is not required for CCRs submitted through ECERT. For assistance with accessing ECERT please email PWSS.CCR@ncdenr.gov or go to <https://pws.ncwater.org/ECERT/pages/CCRHELP.pdf>

If you do not have access to the internet, you can mail your CCR, Certification form, and supporting documentation to: *Public Water Supply Section, 1634 Mail Service Center, Raleigh, NC 27699-1634, Attn: CCR Rule Manager* or FAX your CCR, Certification form, and supporting documentation to (919) 715-6637, Attn: CCR Rule Manager

2022 Annual Drinking Water Quality Report

Stokes County WASA

Water System Number: NC 0285025

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.

We are pleased to present to you this year's Annual Drinking Water Quality Report. This report is a snapshot of last year's water quality. Included are details about your source(s) of water, what it contains, and how it compares to standards set by regulatory agencies. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water and to providing you with this information because informed customers are our best allies. **If you have any questions about this report or concerning your water, please contact Stewart Easter at (336) 593-2415. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. The Stokes County Board of Commissioners' will meet each month on the 2nd Monday at 6:00 pm and 4th Monday at 2:00 pm. The Board of Commissioners will conduct its regular meetings in the Commissioners' Chambers located on the 2nd Floor of the Administrative Building 1014 Main Street Danbury, NC.**

What EPA Wants You to Know

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Stokes County WASA is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

When You Turn on Your Tap, Consider the Source

The water that is used by this system is surface water from the Yadkin River, treated by and purchased from Winston-Salem.

Source Water Assessment Program (SWAP) Results

The North Carolina Department of Environmental Quality (DEQ), Public Water Supply (PWS) Section, Source Water Assessment Program (SWAP) conducted assessments for all drinking water sources across North Carolina. The purpose of the assessments was to determine the susceptibility of each drinking water source (well or surface water intake) to Potential Contaminant Sources (PCSs). The results of the assessment are available in SWAP Assessment Reports that include maps, background information and a relative susceptibility rating of Higher, Moderate or Lower.

The relative susceptibility rating of each source for Winston-Salem/ Stokes County was determined by combining the contaminant rating (number and location of PCSs within the assessment area) and the inherent vulnerability rating (i.e., characteristics or existing conditions of the well or watershed and its delineated assessment area). The assessment findings are summarized in the table below:

Susceptibility of Sources to Potential Contaminant Sources (PCSs)

Source Name	Susceptibility Rating	SWAP Report Date
Salem Lake	Higher	September 2020
Yadkin River(Idols Dam)	Higher	September 2020
Yadkin River (PW Swann WTP)	Moderate	September 2020

The complete SWAP Assessment report for Winston-Salem/ Stokes County may be viewed on the Web at:

<https://www.ncwater.org/?page=600> Note that because SWAP results and reports are periodically updated by the PWS Section, the results available on this web site may differ from the results that were available at the time this CCR was prepared. If you are unable to access your SWAP report on the web, you may mail a written request for a printed copy to: Source Water Assessment Program – Report Request, 1634 Mail Service Center, Raleigh, NC 27699-1634, or email requests to swap@ncdenr.gov. Please indicate your system name, number, and provide your name, mailing address and phone number. If you have any questions about the SWAP report please contact the Source Water Assessment staff by phone at 919-707-9098.

It is important to understand that a susceptibility rating of “higher” does not imply poor water quality, only the system’s potential to become contaminated by PCSs in the assessment area.

Help Protect Your Source Water

Protection of drinking water is everyone’s responsibility. You can help protect your community’s drinking water source(s) in several ways: (examples: dispose of chemicals properly; take used motor oil to a recycling center, volunteer in your community to participate in group efforts to protect your source, etc.).

Violations that Your Water System Received for the Report Year

During 2022, or during any compliance period that ended in 2022, we received No violations.

Important Drinking Water Definitions:

- **Not-Applicable (N/A)** – Information not applicable/not required for that particular water system or for that particular rule.
- **Non-Detects (ND)** - Laboratory analysis indicates that the contaminant is not present at the level of detection set for the particular methodology used.
- **Parts per million (ppm) or Milligrams per liter (mg/L)** - One part per million corresponds to one minute in two years or a single penny in \$10,000.
- **Parts per billion (ppb) or Micrograms per liter (ug/L)** - One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.
- **Parts per trillion (ppt) or Nanograms per liter (nanograms/L)** - One part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.
- **Nephelometric Turbidity Unit (NTU)** - Nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.
- **Variances and Exceptions** – State or EPA permission not to meet an MCL or Treatment Technique under certain conditions.
- **Action Level (AL)** - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- **Treatment Technique (TT)** - A required process intended to reduce the level of a contaminant in drinking water.
- **Maximum Residual Disinfection Level (MRDL)** – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- **Maximum Residual Disinfection Level Goal (MRDLG)** – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **Locational Running Annual Average (LRAA)** – The average of sample analytical results for samples taken at a particular monitoring location during the previous four calendar quarters under the Stage 2 Disinfectants and Disinfection Byproducts Rule.
- **Running Annual Average (RAA)** – The average of sample analytical results for samples taken during the previous four calendar quarters.
- **Level 1 Assessment** - A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
- **Level 2 Assessment** - A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
- **Maximum Contaminant Level (MCL)** - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- **Maximum Contaminant Level Goal (MCLG)** - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Water Quality Data Tables of Detected Contaminants

We routinely monitor for over 150 contaminants in your drinking water according to Federal and State laws. The tables below list all the drinking water contaminants that we detected in the last round of sampling for each particular contaminant group. The presence of contaminants does not necessarily indicate that water poses a health risk. **Unless otherwise noted, the data presented in this table is from testing done January 1 through December 31, 2022.** The EPA and the State allow us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

Stokes County WASA

REVISED TOTAL COLIFORM RULE:

Microbiological Contaminants in the Distribution System

Contaminant (units)	MCL Violation Y/N	Number of Positive/Present Samples	MCLG	MCL	Likely Source of Contamination
Total Coliform Bacteria (presence or absence)	N/A	N/A	N/A	TT*	Naturally present in the environment
<i>E. coli</i> (presence or absence)	No	0 / Absent	0	Routine and repeat samples are total coliform-positive and either is <i>E. coli</i> -positive or system fails to take repeat samples following <i>E. coli</i> -positive routine sample or system fails to analyze total coliform-positive repeat sample for <i>E. coli</i> Note: If either an original routine sample and/or its repeat samples(s) are <i>E. coli</i> positive, a Tier 1 violation exists.	Human and animal fecal waste

* If a system collecting fewer than 40 samples per month has two or more positive samples in one month, an assessment is required.

Lead and Copper Contaminants

Contaminant (units)	Sample Date	Your Water (90 th Percentile)	Number of sites found above the AL	MCLG	AL	Likely Source of Contamination
Copper (ppm) (90 th percentile)	August 2020	ND	0	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits
Lead (ppb) (90 th percentile)	August 2020	ND	0	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits

Disinfectant Residuals Summary

	MRDL Violation Y/N	Your Water (highest RAA)	Range Low High	MRDLG	MRDL	Likely Source of Contamination
Chlorine (ppm)	N	0.70 ppm	0.32 – 1.03 ppm	4	4.0	Water additive used to control microbes

Stage 2 Disinfection Byproduct Compliance - Based upon Locational Running Annual Average (LRAA)

Disinfection Byproduct	Year Sampled	MCL Violation Y/N	Your Water (highest LRAA)	Range Low High	MCLG	MCL	Likely Source of Contamination
TTHM (ppb)	2022	N			N/A	80	Byproduct of drinking water disinfection
Location B01			58 ppb	25 – 105 ppb			
HAA5 (ppb)	2022	N			N/A	60	Byproduct of drinking water disinfection

Location B01		22 ppb	16 – 31 ppb	
--------------	--	--------	-------------	--

Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

Results from Winston-Salem's CCR

The following substances were detected in Winston-Salem/Forsyth County public water supply during the 2022 calendar year.

Regulated at the Treatment Plant					
Substance	Highest Level Allowed (EPA's MCL ¹)	Ideal Goal (EPA MCLG ²)	Range of Detections	Average Level Detected	Source
Fluoride, ppm ⁵	4.0 ⁶	4.0	0.06 - 1.20	0.82	Erosion of natural deposits; Water additive, promotes strong teeth
Orthophosphate, ppm	NA	1.0	0.732 - 1.137 ¹¹	0.91	Water treatment additive to prevent pipe corrosion
Total Organic Carbon, ppm	Treatment Technique ⁷	n/a	0.895 - 1.910	1.260	Naturally present in the environment
Turbidity, NTU ⁸	Treatment Technique ⁹	n/a	0.020 - 0.295	0.040	Soil erosion
Regulated in the Distribution System					
Total Trihalomethanes, ppb ⁴	80 LRAA ¹⁰	0.0	13.8 - 123.6	49.0	Byproducts of drinking water disinfection
Total Haloacetic Acids (5), ppb	60 LRAA ¹⁰	0.0	13.9 - 57.4	31.9	Byproducts of drinking water disinfection
Chlorine, ppm	4.0	4.0	0.03 - 1.92	0.95	Water treatment additive for disinfection
Total Coliforms	Less than 5% positive	0.0	ND - 0.54% ¹⁵	0.05%	Naturally present in the environment
Unregulated Substances at the Treatment Plant - Point of Entry ¹⁴					
Geosmin, ppt ³	Not Regulated	Not Regulated	ND - 8.71	4.21	Byproduct of algae growth ¹²
2-methylisoborneol, ppt	Not Regulated	Not Regulated	ND - 7.32	1.60	Byproduct of algae growth ¹²
Unregulated Substances at the Treatment Plant - Source Water ¹⁴					
Geosmin, ppt	Not Regulated	Not Regulated	ND - 8.05	3.52	These compounds are used in the manufacture of carpets, clothing, fabrics for furniture, paper packing for foods and other materials. They are also used in the manufacturing of non-stick cookware, fire-fighting foams and a number of different manufacturing processes.
2-methylisoborneol, ppt	Not Regulated	Not Regulated	ND - 16.20	5.24	
Perfluorooctanesulfonic acid (PFOS), ppt	Not Regulated ¹³	Not Regulated	ND - 1.58	0.61	
Perfluorooctanoic acid (PFOA), ppt	Not Regulated ¹³	Not Regulated	ND - 1.07	0.41	

Constituent	Annual Range Detected	Annual Average
Alkalinity, ppm	10.5 - 30.5	22.3
Calcium, ppm	2.8 - 5.1	3.7
Carbon Dioxide, ppm	1.5 - 15.0	3.6
Chlorine, ppm	0.72 - 2.11	1.45
Conductivity, micromhos/cm	87.1 - 134.1	105.1
Hardness, ppm	12.0 - 32.0	19.2
Magnesium, ppm	1.4 - 2.4	1.9
pH, Standard Units	6.9 - 8.1	7.5
Phosphate, ppm	0.77 - 1.29	0.97
Potassium, ppm	1.5 - 3.5	2.3
Silica, ppm	3.67 - 15.70	8.92
Sodium, ppm	8.5 - 19.4	12.2
Temperature, Deg. C	3.0 - 30.0	18.1