



Temple Fire & Rescue

Occupancy: **CITY OF TEMPLE FIRE STATION 1**
Occupancy ID: **2802**
Address: **210 N 3RD STS**
TEMPLE TX 76501

Inspection Type: **Food Truck Insp.**

Inspection Date: **1/14/2021**

By: Whitlock, Micah (116572)

Time In: **08:50**

Time Out: **00:00**

Authorized Date: **01/14/2021**

By: Whitlock, Micah (116572)

Form: Food Truck Insp.

Inspection Description:

Annual inspection of food truck (Mobile Food Unit), all applicable items must pass for operation in the city limits of Temple, Tx.

Inspection Topics:

Location

Fire Hydrant

Mobile units must remain at least 15 Feet away from any fire hydrant or fire department connection (FDC)

Status:

Notes:

Location Of The Unit

Units shall not be located closer than 20 feet to any structure

Status:

Notes:

Entrances and Exits

Mobile units shall not obstruct any entrances or exits from a structure

Status:

Notes:

Unit Exits

Exits of mobile unit shall not be obstructed

Status:

Notes:

Electrical / Generator

Electrical Supply

Mobile units shall not use electricity from a nearby structure unless designed and rated for use (appropriate outlet, breakers, cord, etc.)

Status:

Notes:

Extension Cords

No use of excessive extension cords or extension cords not rated for load being pulled.

Status:

Notes:

Breaker Boxes

Breaker boxes and junction boxes shall have proper cover and be water resistant (if location can be exposed to water)

Status:

Notes:

Wiring of Unit

All wiring of the mobile unit must be in conduit

Status:

Notes:

Accessories

Improper use of electrical accessories and overloading of circuits is prohibited

Status:

Notes:

Generator Refueling

Fuel that is used to refill generators must be kept at a safe distance from generator or ignition source. Generator must be shut off and cool before refueling.

Status:

Notes:

Generator Placement

Generator may not be placed in a location near combustibles or near an area that will not ventilate CO emissions.

Status:

Notes:

Propane Cylinders

Requalification of Cylinders

Propane Cylinders need to be requalified every 12 years. A current date of manufacture if its a new tank, or a requalification stamp is required on all cylinders.

Status:

Notes:

Cylinders

A maximum of two-100lb propane cylinders are allowed. One is allowed one for use and one for a spare. The cylinders cannot be manifolded together.

Status:

Notes:

Propane leak

Propane cylinders will be turned on and lines, cylinders and devices will be checked.

Status:

Notes:

Cylinder Components

All visible components of system to be visually inspected; shutoff valve, regulators, no visible defects, etc.

Status:

Notes:

Propane Cylinder Location

Location and Mounts

Propane cylinders, including spares, shall not be located; below the lowest part of the vehicle frame, inside improperly vented or unvented trunks or beds of vehicles, inside passenger compartments of vehicles, or on the ground. All propane cylinders must be secured and mounted appropriately.

Status:

Notes:

Fire Extinguishers

Class K Extinguisher

If cooking method produces grease laden vapors provide appropriate size class K extinguisher (mounted and tagged in date).

Status:

Notes:

5LB ABC Extinguisher

5 LB ABC extinguisher mounted and tagged in date.

Status:

Notes:

Hood Suppression

Automatic Fire Suppression System

Hood suppression system installed (where applicable) and tagged in date.

Status:

Notes:

Additional Time Spent on Inspection:

Category	Start Date / Time	End Date / Time
Notes: No Additional time recorded		

Total Additional Time: 0 minutes

Inspection Time: 0 minutes

Total Time: 0 minutes

Summary:

Overall Result: Passed

Inspector Notes:

Closing Notes:

For any further questions contact the Temple Fire Marshal's Office at 254-298-5682

Inspector:

Name: Whitlock, Micah

Rank: Driver

Work Phone(s): None on file

Email(s): mwhitlock@templetx.gov

Signature

Date

Representative Signature:

Signature

Date